

[Print](#) | [Close Window](#)

Subject: Planning commission meeting 5-20-20. Drought Contingency Plan
From: Jacques Beaupre <jcqs.beaupre@gmail.com>
Date: Wed, May 20, 2020 10:39 am
To: azetter@trinidad.ca.gov, Gabe Adams <cityclerk@trinidad.ca.gov>, Trinidad City Manager <citymanager@trinidad.ca.gov>

Dear City of Trinidad,

I am a homeowner and permanent year round resident of Trinidad. I do my best to make this City a better place.

Recent history shows the water system does not have a lot of water to spare in dry years. As recent as 2015 we were under state wide drought conditions and the City needed to cut back it's use of water. This was with the current number of water connections.

There is a elephant in the room with the discussion of the Drought Contingency Plan.

What is going to happen when our water supply is connected to a large commercial venture built by the Cher-Ae Heights Trinidad Rancheria that Trinidad has no control over?

This is not just a hotel but a large casino expansion and shopping resort complex that is planned.

Thank you,

Jacques Beaupre
231 Parker Creek Drive
P O Box 1177
Trinidad, CA 95570
707-499-8309

Copyright © 2003-2020. All rights reserved.

[Print](#) | [Close Window](#)

Subject: Question for discussion during the Trinidad Planning Commission Meeting on May 20, 2020

From: Richard Clompus <rclompus@mac.com>

Date: Sun, May 17, 2020 10:28 pm

To: azetter@trinidad.ca.gov

Cc: Richard Clompus OD <rclompus@mac.com>

The GHD water report dated October 29, 2019 indicated on page 5 that the only fire hydrant in Trinidad that did not meet the fire flow requirement was located on Van Wycke Street due to:

"a damaged pipe that runs from Edward Street west down Van Wycke Street. The broken and capped pipe causes flow to this section to be routed through a smaller pipe. While there is sufficient capacity for normal flow conditions, fire flow conditions cause pressure conditions to drop below threshold levels. This situation could be resolved by repairing the broken/capped pipeline."

I would like to understand the steps planned in 2020 to remediate this fire safety issue. Thank you for your time and attention.

Be well,
Richard

Richard Clompus
m 904-501-5309
860 Van Wycke Street
Trinidad, California

Copyright © 2003-2020. All rights reserved.